

SECTION 1 – INTRODUCTION

1.01 The following Rules and Regulations shall be and are hereby declared to be the Rules and Regulations governing the use of Manasquan River Regional Sewerage Authority Facilities and the discharge of sewage and industrial waste therein, and the schedule of user charges for the Manasquan River Regional Sewerage Authority.

SECTION 2 – PURPOSE

2.01 The purpose of these Rules and Regulations are as follows:

1. To prohibit the discharge into the Regional Authority's System and thence to the Ocean County Utilities Authority's System of any wastewaters that are not in compliance with any Federal standards promulgated pursuant to the Federal Water Pollution Control Act Amendments of 1972 (FWPCAA), the Clean Water Act of 1977 (CWA), and any subsequent revisions or amendments to said Federal Acts and any other applicable Federal Regulations.
2. To ensure that all wastewaters discharged to the County Authority treatment works and Regional Authority are in compliance with the Federal Water Pollution Control Act Amendments of 1972, the Clean Water Act of 1977, and/or any subsequent applicable Federal legislation.
3. To require the pretreatment of all wastewaters discharged into the Regional Authority's System for which categorical pretreatment standards have been promulgated pursuant to Federal or State legislation by the U.S. Environmental Protection Agency pursuant to the Federal Water Pollution Control Act Amendments of 1972 (FWCPAA), the Clean Water Act of 1977 (CWA), the New Jersey State Department of Environmental Protection, the County Authority and/or by the Regional Authority.
4. To prohibit the discharge of any wastewaters into the treatment works of a flammable nature or which may create in any way a poisonous or hazardous environment for maintenance and operating personnel.
5. To prohibit the discharge of any wastewaters into the treatment works which may affect its integrity or cause operational or maintenance difficulties in it as it is now constructed or as it may be modified, expanded, or improved on in the future.
6. To prohibit or require pretreatment before introduction into the treatment works of any wastewaters which may adversely affect the integrity, operation and/or maintenance of the treatment works by direct or indirect chemical or physical action, or which may interfere with the treatment process.
7. To regulate excessive volumes and/or inordinate rates of discharge of any wastewaters into the treatment works.

8. To regulate the discharge of any wastewaters which require the levying of a surcharge for either their discharge into the Regional Authority's System or for treatment by the County Authority.
9. To prohibit or require pretreatment of wastewaters which are discharged into the Regional Authority System which are malodorous and/or create a public nuisance.
10. To establish flow charges and such other charges for the discharge of wastewater into the Regional Authority's System for processing by the County Authority's system.

SECTION 3 – DEFINITIONS

Unless the context specifically indicates otherwise, the following terms, as used in these Rules and Regulations, shall have the meanings hereinafter designated:

3.01 “MRRSA” or “REGIONAL AUTHORITY” shall mean the Manasquan River Regional Sewerage Authority, a public body politic and corporate of the State of New Jersey which may include a duly appointed deputy, agent, official or representative.

3.02 “OCUA” or “COUNTY AUTHORITY” shall mean the Ocean County Utilities Authority, a public body politic and corporate of the State of New Jersey, which may include a duly appointed deputy, agent, official or representative.

3.03 “Regional Authority’s System” shall mean all facilities constructed or acquired, owned and operated by the Manasquan River Regional Sewerage Authority including but not limited to trunk and interceptor sewers, pumping stations and force mains, flow meters and meter chambers.

3.04 “County Authority’s System” shall mean all facilities constructed or acquired, owned and operated by the Ocean County Utilities Authority for the purpose of conveying, treating and disposing wastewater including but not limited to trunk and interceptor sewers, pumping stations and force mains, flow meters and meter chambers and County Authority Treatment Plant.

3.05 “BOD” (Biochemical Oxygen Demand) shall mean the quantity of oxygen utilized in the biochemical oxidation of organic matter under standard laboratory procedure for five (5) days at 20°C, expressed in milligrams per liter. The standard laboratory procedure shall be as defined in the latest publication of 40CFR Part 136 “Guidelines Establishing Test Procedures for the Analysis of Pollutants.”

3.06 “COD” (Chemical Oxygen Demand) shall mean the quantity of oxygen required for the chemical oxidation of organic matter in a liquid, expressed in milligrams per liter. The standard laboratory procedure shall be as defined in the latest publication of 40CFR Part 136 “Guidelines Establishing Test Procedures for the Analysis of Pollutants.”

3.07 “Company” shall mean any corporation or business enterprise formed under the laws of the State of New Jersey or any other state.

3.08 “Chlorine Demand” shall mean the quantity of chlorine absorbed by a wastewater, allowing a residual of 0.1 PPM by weight after fifteen (15) minutes of contact, expressed in milligrams per liter. The standard laboratory procedure shall be as defined in the latest publication of 40CFR Part 136 “Guidelines Establishing Test Procedures for the Analysis of Pollutants.”

3.09 “Cooling Water” shall mean the water discharged from any use such as air conditioning, cooling or refrigeration, for the purpose of carrying away excess heat and which may contain biocides or similar substances that are used to control biological growth, and is considered an “Industrial Wastewater.”

3.10 “Compatible Pollutant” shall mean BOD, suspended solids, pH and fecal coliform bacteria, oil and grease and such additional pollutants as are now or may be in the

future specified and controlled in the County Authority's applicable NPDES/NJPDES permit for its wastewater treatment plant where said plant has been designed and used to stabilize, reduce or remove such pollutants.

3.11 "CWA" shall mean the Federal Clean Water Act of 1977 as amended.

3.12 "Domestic Wastewater" shall mean liquid wastes or liquid borne waste (i) resulting from the non-commercial preparation, cooking and handling of food and/or (ii) containing human excrement and similar matter from the sanitary conveniences of dwellings, commercial buildings, industrial facilities and institutions.

3.13 "Equivalent Dwelling Unit" shall mean the equivalent wastewater flow from one three bedroom single family dwelling unit and shall be applied to residential, industrial, commercial and other users at an average rate of 300 gallons per day.

3.13.A. "Equivalent Dwelling Unit - Non-Residential Calculation" The Authority's Engineer shall determine the equivalent wastewater flow from the proposed non-residential use by reference to the NJDEP flow standards published within N.J.A.C. 7:14A-23.3 where available; or based upon comparable use flows as determined by the Authority's Engineer using the best available information. The amount of flow determined in gallons per day shall be divided by 300 to determine the number of Equivalent Dwelling Units of sewage to be used to calculate connection fees.

3.13.B. "Equivalent Dwelling Unit – Residential Calculation" shall be based upon the number of bedrooms proposed for each residential dwelling. In computing the equivalent wastewater flow from a proposed residential use to be used to calculate connection fees, the following adjustments shall be made where 1 EDU as defined above equates to 300 gallons per day:

1. Residential dwellings with one bedroom shall be equivalent to 0.50 EDU
2. Residential dwellings with two bedrooms shall be equivalent to 0.75 EDU
3. Residential dwellings with three or four bedrooms shall be equivalent to 1.0 EDU
4. Residential dwellings with more than four bedrooms shall be equivalent to 1.25 EDU

Where a residential dwelling contains more than three bathrooms, and/or more than one kitchen area, and/or more than one laundry area, or provides for some other use on the residential property which will cause additional sewerage flow; the Authority's Engineer shall determine the reasonable amount of additional equivalent sewer usage to be added to the EDU's determined above.

3.14 "FWPCAA" shall mean the Federal Water Pollution Control Act Amendments of 1972.

3.15 "Garbage" shall mean solid wastes resulting from the domestic or commercial preparation, cooking and dispensing of food, and from the handling, storage and sale of produce.

3.16 “Grab Sample” means a sample which is taken on a one-time basis with no regard to the flow and without consideration of time.

3.17 “Hazardous Pollutant” means:

- A. Any toxic pollutant;
- B. Any hazardous substance as defined pursuant to section 3 of P.L. 1976, c.141 (N.J.S.A. 58:10A-3u);
- C. Any substance regulated as a pesticide under the Federal Insecticide, Fungicide and Rodenticide Act, Pub.L. 92-516 (7 U.S.C § 136 et seq.);
- D. Any substance the use or manufacture of which is prohibited under the Federal Toxic Substances Control Act, Pub.L. 94-469 (15 U.S.C § 2601 et. seq);
- E. Any substance identified as a known carcinogen by the International Agency for Research on Cancer; or
- F. Any hazardous waste designated pursuant to section 3 of P.L. 1981, c.279 (N.J.S.A. 13:1E-51) or the “Resource Conservation and Recovery Act,” Pub.L. 94-580 (42 U.S.C § 6901 et seq.)

3.18 “Holding Tank Waste” means any waste from holding tanks such as vessels, chemical toilets, campers, trailers, septic tanks, marina holding tanks and vacuum-pump tank trucks.

3.19 “Incompatible Pollutant” shall mean any pollutant which is not a “compatible pollutant” as defined in this section.

3.20 “Indirect Discharge” means the discharge or the introduction of nondomestic pollutants from any source regulated under Section 307(b) or (c) of the Act, (33 U.S.C 1317), into the POTW (including holding tank waste discharged into the system).

3.21 “Industrial Wastewater” means the wastewater resulting from the processes employed by an industrial or commercial user with any groundwater, surface water, and storm water that may be present, whether treated or untreated, is discharged into a treatment works.

3.22 “Industrial User” means any nonresidential user or users identified in the Standard Industrial Classification Manual, 1987, Office of Management and Budget, as amended and supplemented under one of the following divisions:

- Division A. Agriculture, Forestry, and Fishing
- Division B. Mining
- Division D. Manufacturing
- Division E. Transportation, Communications, Electric, Gas, and Sanitary Services
- Division I. Services

3.23 “Industrial Discharge Permit” means the permit issued by the County Authority to certain users which allows for the discharge of industrial wastewater with certain characteristics into the treatment works.

3.24 “Industrial Wastewater” means the wastewater resulting from the processes employed by an industrial or commercial user with any groundwater, surface water, and storm water that may be present, whether treated or untreated, is discharged into a treatment works.

3.25 “Interference” shall mean (i) inhibiting or disrupting of the OCUA treatment works system or its treatment process so as to contribute to, or cause a violation of any condition of its state or federal permit under which the County Authority operates; or (ii) discharging industrial process wastewater which, in combination with existing domestic flows are of such volume and/or strength as to exceed the domestic treatment process design capacity; or (iii) preventing the use or disposal of sludge produced by the OCUA treatment works in accordance with section 405 of the Federal Clean Water Act of 1977 (33 U.S.C. 1251 *et. seq.*) and the New Jersey Guidelines for the Utilization and Disposal of Municipal and Industrial Sludge and Septage; or any regulations or criteria or guidelines developed pursuant to the Federal Resource Conservation and Recovery Act of 1976 (42 U.S.C. 3251 *et. seq.*), the Federal Clean Air Act (42 U.S.C. 7401 *et. seq.*), and the Federal Toxic Substances Control Act (15 U.S.C. 2601 *et. seq.*).

3.26 “NJDEP” shall mean the New Jersey Department of Environmental Protection.

3.27 “National Pollutant Discharge Elimination System” (NPDES) means the national program for issuing, modifying, revoking, terminating, monitoring and enforcing discharge permits and enforcing pretreatment requirements under Sections 307, 402, 318 & 405 of the Clean Water Act of 1977 (33 U.S.C. 1251 *et. seq.*).

3.28 “New Source” means any building, structure, facility or installation from which there is or may be a discharge of pollutants, the construction of which commenced after the publication of proposed Pretreatment Standards under section 307(c) of the Federal Water Pollution Control Act which will be applicable to such source if such Standards are thereafter promulgated in accordance with that section, *provided that*;

- A. The building, structure, facility or installation is constructed at a site at which no other source is located; or
- B. The building, structure, facility or installation totally replaces the process or production equipment that causes the discharge of pollutants at an existing source; or
- C. The production or wastewater generating processes of the building, structure, facility or installation are substantially independent of an existing source at the same site.

3.29 “Participant Municipality” shall means the Boroughs of Farmingdale and Freehold and the Townships of Howell, Freehold, and Wall, municipal corporations of the State of New Jersey, (hereinafter singularly referred to as “Participant” and in general referred to as “Participant”). Also included under this definition is a municipal utility authority or sewerage authority established by any of the participating municipalities and empowered to collect and convey sewage to the Regional Authority.

3.30 “Person” shall mean any participant, customer, individual, firm, company, partnership, corporation, association, group or society, and includes the State of New

Jersey, and agencies, districts, commissions and political subdivisions created by or pursuant to State Law.

3.31 “pH” shall mean the logarithm of the reciprocal of the concentration of hydrogen ions in moles per liter of solution.

3.32 “Pretreatment” shall mean the application of physical, chemical and biological wastewater treatment processes to reduce the amount of pollutants in, or alter the nature of the pollutant properties of, an industrial wastewater prior to discharging such wastewater into the Regional Authority’s system.

3.33 “Pretreatment Standards” shall mean all applicable Federal rules and regulations implementing section 307 of the Act (CWA), as well as any non-conflicting State or County Authority Standards. In cases of conflicting standards or regulations, the more stringent thereof shall be applied.

3.34 “Prohibited Pollutants” means any pollutant in amounts exceeding standards promulgated by the EPA or any subsequent Federal legislation of the EPA pursuant to Section 307(a) of the Clean Water Act of 1977, including, but not limited to, those listed on Tables 1 and 2 and in Ocean County Utilities Authority’s Rules and Regulations, Appendices A-1 and A-2, and those chemical elements or compounds, phenols or other tastes or odor-producing substances, or any other substances normally not found in unpolluted waters which are not susceptible to treatment or which may interfere with the biological processes or efficiency or which will pass through the treatment works plant.

3.35 “Properly Shredded Garbage” shall mean the wastes from the preparation, cooking and dispensing of food that have been shredded to such a degree that all particles will be carried freely under the flow conditions normally prevailing in sanitary sewers, with no particle greater than one-half (1/2) inch in any dimension.

3.36 “Publicly Owned Treatment Works” or “POTW” means any device or system used in the storage and treatment (including recycling and reclamation) of municipal sewage or industrial wastes of a liquid nature which is owned by a State or municipality. This definition includes sewers, pipes, or other conveyances only if they convey wastewater to a POTW providing treatment. Treatment works associated with potable water treatment and solid waste facilities shall be considered industrial treatment works.

3.37 “Regional Administrator” means the Administrator of Region II of the United States Environmental Protection Agency or his/her authorized representative.

3.38 “Sanitary Sewer” shall mean a sewer that carries liquid and water-carried wastes from residences, commercial buildings, industrial plants and institutions together with minor quantities of ground, storm, and surface waters that are not admitted intentionally.

3.39 “Shall” is mandatory; “Will” is mandatory; “May” is permissive.

3.40 “Significant Industrial User” shall mean any industrial user who discharges into the treatment works, industrial wastewater which either (1) exceeds 25,000 gallons per day, or (2) exceeds the mass equivalent of 25,000 gallons per day of waste based upon a

BOD of 300 mg/l, a COD of 500 mg/l or suspended solids of 300 mg/l, or (3) contributes five percent or more of the daily mass loading of any of the pollutants listed in Table 1 and/or in Appendix A-1 and A-2 of the Sewer Use Rules and Regulations of the County Authority, or (4) constitutes an industrial user subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N or (5) has the reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement.

3.41 "Slug" means any discharge of a non-routine, episodic nature, including but not limited to, an accidental spill or a non-customary discharge.

3.42 "Storm Drain" (sometimes termed "storm sewer") shall mean a sewer which carries storm and surface waters and drainage, but excludes sewage and industrial wastes other than Cooling Water.

3.43 "Storm Water" shall mean any flow occurring during or immediately following any form of natural precipitation and resulting therefrom.

3.44 "Surcharge" means the additional charge that will be levied against a Participant or a person discharging wastewater whose BOD and/or suspended solids concentrations are in excess of 300 ppm, or which contain constituents in concentrations for which the Authority has determined an additional charge is required for their treatment.

3.45 "Total Suspended Solids" shall mean solids that either float on the surface of, or are in suspension in water, wastewater or other liquids, expressed in milligrams per liter. The standard laboratory procedure shall be as defined in the latest publication of 40CFR Part 136 "Guidelines Establishing Test Procedures for the Analysis of Pollutants."

3.46 "Treatment Works" means any device or system whether public or private, used in the storage, treatment, or conveyance of domestic or industrial waste of a liquid nature including intercepting sewers, outfall sewers, sewage collection systems and pumping stations as defined in N.J.A.C. 7:14A.

3.47 "Unit" shall mean a dwelling unit or a portion of a structure normally occupied by a single family.

3.48 "Unpolluted Water" shall mean water not containing any pollutants limited or prohibited by the effluent standards in effect, or water whose discharge will not cause any violation of receiving water quality standards.

3.49 "USEPA/EPA" shall mean the United States Environmental Protection Agency.

3.50 "User" shall mean any person who discharges, causes or permits the discharge of wastewater into the Regional Authority's System.

3.51 "Standard Industrial Classification" (SIC) means a classification pursuant to the North American Industrial Classification System (NAICS) Manual of 1997, as revised from time to time, prepared by the United States Office of Management and Budget.

3.52 “Wastewater” means the liquid and water-carried industrial or domestic wastes from dwellings, commercial buildings, industrial facilities, and institutions, together with any groundwater, surface water, and storm water that may be present, whether treated or untreated, which is discharged into or permitted to enter the Regional Authority’s System.

3.53 “Wastewater Treatment Plant” shall mean an arrangement of devices and structures for treating wastewater, industrial wastes, and sludge, as defined in POTW.

3.54 Terms not otherwise defined herein shall be as adopted in the latest publication of 40CFR Part 136 “Guidelines Establishing Test Procedures for the Analysis of Pollutants,” published by the American Public Health Association, the American Water Works Association and the Water Pollution Control Federation; the Federal Guideline for State and Local Pretreatment Programs, Volume I, 1977, or the latest revision thereof; or the Sewer Use Rules and Regulations of the Ocean County Utilities Authority available at www.OCUA.com.

SECTION 4 – APPLICATION FOR SEWERAGE SERVICES

4.01 Applications: All proposed sewer connections, sewer extensions, or wastewater treatment facilities for residential or commercial uses, where the number of dwelling units or equivalent dwelling units (EDU's) to be served is one or more, or for industrial uses regardless of size, which are located within the Regional Authority's service area are required to file an Application with the Regional Authority to obtain sewerage service. This specifically includes any vacant land which obtains a building permit to construct a residential, commercial or industrial use which will connect into a Participant's existing sewerage system. Existing residential, commercial and industrial structures and uses, which are converting from septic systems to connection to a Participant's sewerage system or existing sewer uses which are expanded or changed to a use which produces the greater of 1 equivalent dwelling unit (EDU) of wastewater or increases the previously approved wastewater flow by 10% or more, shall also be required to file an Application with the Regional Authority to obtain approval for initial or increased sewerage service.

Those developments which require municipal minor or major subdivision or site plan approvals for the development of a property which will connect into a Participant's sewer system, shall not file an Application with the Regional Authority for review and approval until the development has obtained at least preliminary Participant municipality Planning Board or Zoning Board of Adjustment approval, or the equivalent if it is an exempt subdivision or site plan.

All approvals are granted for a two year period. If requested in writing by the Applicant prior to the expiration of the two year approval period, the Regional Authority may grant a one year extension for good cause shown. All construction work on the sewer extensions or treatment facilities, weather conditions and availability of required sewer construction materials permitting, must be completed within the approval period. If construction work on the sewer extension or connection system has not begun before the end of the approval period, the approval shall automatically become void and before construction can begin, an Applicant must re-apply for and obtain an updated approval. Applications must be made on prescribed forms furnished by the Regional Authority which must be accompanied by all relevant supporting documents required for a complete review of the project by the Regional Authority's Engineer and staff. The required documents are listed on the Authority's Application for Sewer Service form.

Application, inspection, review and connection fees are determined and revised periodically in conformance with the applicable provisions of N.J.S.A. 40:14A-1 et seq. The Application fee payment must be paid, together with the scheduled escrow deposits at the time the Application is filed. In addition, a connection fee per equivalent dwelling unit of sewerage (EDU's) must be paid to the Regional Authority for each residential, commercial and/or industrial development that will connect to a Participant's sewerage system within the Regional Authority's service area, prior to the Regional Authority releasing the Resolution and/or any endorsed forms for the approved development. The Regional Authority shall provide to the Building Department in each Participant municipality a map of its service area within that municipality, as well as a verification form to be utilized by each Building Department to verify whether all fees due to the Regional Authority have been paid prior to the issuance of the first building permit. Connection fees due to the Regional Authority may be paid by an Applicant at any time

prior to the Regional Authority releasing the Approval Resolution and the endorsed sewer extension documents, subject however to the following:

- (a) The amount of the connection fee to be paid shall be the amount provided for in Exhibit A Fee Schedule – Schedule C, at the time the payment is made.
- (b) For any application made for a development which received municipal subdivision and/or site plan approval from a participant municipality, if the connection fee is not paid at the time that the Application is filed with the Regional Authority, and/or within thirty(30) days after the adoption by the Authority of an approval Resolution, the Applicant shall enter into a Developer's Agreement with the Regional Authority to be signed by the Applicant, the Regional Authority and the owner of the real estate to which the approval applies (if the owner is a different person or entity than the Applicant) in recordable form to be prepared by the Attorney for the Regional Authority and recorded in the Monmouth County Clerk's Office, at the cost of the Applicant. Only site plan "phased in" applications will be eligible to enter into a Developer's Agreement.
- (c) If the Application approved by the Regional Authority is for a residential subdivision or residential site plan containing more than two dwelling units, the connection fees for all dwelling units in the approved subdivision or site plan shall be due and payable to the Regional Authority before the Resolution and/or endorsed documents are released by the Authority to the Applicant, unless the project has been approved as a phased development, and application to the Regional Authority has been made on a phased basis and a Developer's Agreement has been prepared and executed. In such event, the connection fees for the first phase shall be paid before the endorsed documents are released.
- (d) For those developments for which Applications have been approved by the appropriate Participant municipality land use board to develop a subdivision and/or site plan in phases, connection fees may be paid at the election of the Applicant on a phased basis, subject to the Applicant and Regional Authority entering into a Developer's Agreement. Payments shall be in the amount of edu's calculated or the size and type of approved development within each phase as determined by the Regional Authority's Engineer so that connection fees for each phase are paid to the Authority for all edu's within each phase before the time that the first building permit is issued for each phase. The connection fee of the first phase of a phased project must be paid in full to the Authority before the release of Authority endorsements to the Applicant.
- (e) Owners of existing buildings or structures being refurbished or expanded and/or connecting to the sewer system for the first time shall be required to submit an Application form and pay connection fees prior to a plumbing permit being issued..

- (f) For buildings or structures presently receiving sewerage service that are undergoing renovations resulting in an expansion or change of use, the amount of the connection fees shall be computed based upon the increase in the estimated sewage flow that will be generated as a result of the building renovation or change in the type or intensity of use, and shall be paid to the Regional Authority prior to the Approval Resolution and any endorsed sewer extension documents being released, or if there are no documents to be endorsed, prior to the Participant's issuance of the building permit. If the renovation, expansion, or change in use results in a decrease in the estimated sewage flow from a particular building or structure, the additional connection fee shall be \$0.00.

The Regional Authority charges to an Applicant and the Applicant is required to pay all costs for engineering review of the applicant's plans, for engineering inspection of direct connections to the Regional Authority's facilities, and related legal and administrative costs incurred. An application for inspection shall be filed with the Regional Authority when a direct physical connection to a Regional Authority facility is proposed. An applicant, as part of the filing of its application is required to submit escrow deposits in accordance with the amounts shown on Exhibit A Fee Schedule - Schedule D to defray the Authority's costs for these services. The Authority will audit the escrow account and notify the Applicant if any additional deposits are required to be made by the Applicant to cover the projected engineering or other administrative costs that the Authority will incur, prior to or as a condition of the application being approved and completed. Any excess deposit remaining in the applicant's escrow account at the completion of the Applicant's project shall be returned by the Regional Authority to the Applicant upon the Applicant's written request.

In the event an "Application for Sewer Extension" has been rejected, or if the term of an Approved Application has expired, or if the previously approved plans are revised in any way by the applicant for any reason, the Applicant must reapply to the Regional Authority for new or amended approval before connecting to the sewer system. Each re-application must be accompanied by the payment of a non-refundable re-application fee and an escrow fee computed at one-half of the initial escrow fees under Schedule D together with all relevant documentation required for a proper review.

The Regional Authority will take no formal action granting approval on any application for sewerage service until all required application and escrow deposit fees pursuant to Exhibit A - Schedules C and D of the fee schedule have been paid. These provisions shall apply to all proposed new or increased use sewer connections within the geographical limits of the Participant Municipalities being served by the Regional Authority, whether the proposed connection or increased use connects directly into a permitted Regional Authority line, or into a Participant Municipality, municipal authority, or public utility sewer system connected to a Regional Authority sewer line.

All industrial users presently connected to or tributary to Regional Authority sewer facilities, as well as all new industrial users shall be required to apply for and obtain a Discharge Permit in accordance with Article VII, Notification, Inspection, Testing and Control for Industrial Wastewaters and Article VIII, Discharge Permit System of the Ocean County Utilities Authority. The OCUA Sewer Use Rules and Regulations are available at www.OCUA.com or directly from the OCUA at its main office. The OCUA Sewer Use Rules and Regulations apply to any sewerage that utilizes the Regional Authority's

conveyance system as if the OCUA Sewer Use Rules and Regulations were set forth herein at length, being incorporated herein by reference. Copies of all correspondence, permits and actions by the NJDEP, the Ocean County Utilities Authority and Participant municipalities with the Applicant regarding sewer service shall also be filed with the Regional Authority.

In the event that any portion of the Applicant's project site contains freshwater wetlands as mapped by NJDEP or 100-Year Flood Plain as shown on FEMA Flood Insurance Rate Maps, then the Applicant shall be required to complete applications, pay such escrow and/or fees that may be required to obtain a USEPA Mapping Waiver, the obtaining of which is a condition of the Regional Authority's approval.

4.02 Direct Connections to the Regional Authority System

1. Only a Participant municipality will be allowed to make direct connections and discharge to the Regional Authority System.
2. No Participant municipality shall uncover, connect with, make any opening into, or use in any manner, any sewer or facility of the Regional Authority System for connecting local collection sewerage systems without first making application and receiving the prior written consent of the Authority.
3. Prior to making any direct connection to the Regional Authority System, the Participant Municipality shall submit the complete plans and specifications with the appropriate properly completed forms required in the Application package for the proposed connections which shall be reviewed by the Authority within 90 days. Upon receipt of approval from the Authority, the Participant shall file an Application for Inspection of Direct Connection and pay appropriate inspection fees at least fifteen (15) days before such connection is to be made so that the Authority may supervise and inspect the connection work. No connection work is to be performed in the absence of a Regional Authority Representative.
4. All permitted direct connections to the Regional Authority System will be made at existing manholes located on our interceptor sewer. Connections directly to the interceptor sewers or the installation of new manholes will not be allowed.
5. Individual business, commercial and house connections, known as laterals, will not be permitted to be made directly to the Regional Authority's interceptor sewer.
6. The Regional Authority System has been constructed with regional connection points for Participant Municipality connection. Stub sewers provided in these manholes shall be used by the Participant. If regional connection points are not available, or if it is not feasible to connect via gravity, new regional (Participant) connection points may be considered by the Authority.

7. Where possible and practicable, all connections to the Authority's interceptor sewer will be made at an invert elevation where the 0.8 depth point of both sewers are at the same elevation.
8. All connection lines installed between the Regional Authority System and the Participant's Local Collection Sewerage System will become the property of the Participant and maintained by the Participant.
9. Notification of the connection date and time must be received by the Authority at least 72 hours in advance of a connections' construction.
10. If the Authority is not notified about a connection in accordance with (L) above, then the participant, applicant, or user, at it's own expense, may be required to uncover the connection to permit a thorough inspection to be made. If the inspection discloses an unsatisfactory connection, the participant, applicant, or user will be required to correct the connection at it's own expense. All additional costs of inspection by the Authority Engineer will be borne by the participant.

SECTION 5 – PROHIBITED DISCHARGES

5.01 Prohibitions on Wastewater Discharges

No person shall discharge, deposit, cause or allow to be discharged or deposited into the Regional Authority System any wastewater which causes pass through or interference, contributes to a violation of any of the parameters in the County Authority's NJPDES permit, does not meet applicable pretreatment requirements, or which contains any of the following:

1. Storm water, surface water, groundwater, roof runoff, subsurface drainage, swimming pool water..
2. Oils, tar, grease, combustible gases and liquids, insoluble solids of any kind, or other substances which would impair, impede, affect, interfere with or endanger the Regional Sewerage System or any part thereof.
3. Gasoline, naphtha, paints, lacquers, fuel oil, or other flammable or explosive liquid, solid, or gas which by reason of its nature or quality may cause fire or explosion or which, in any way, may be injurious to personnel or the Regional Sewerage System.
4. Substances of such a nature as to form noxious or malodorous gases or substances which either singularly or through interaction with other substances found in wastewater create a public nuisance as defined in Section 2.1B of the Public Health Nuisance Code of the State of New Jersey, hazard to life, or prevent entry into any portion of the Regional Sewerage System for operational duties, maintenance or repair.
5. Solids or viscous substances in quantities or of such size capable of causing obstruction to the flow in sewers, or other interference with the proper operation of the Regional Sewerage System such as, but not limited to, ashes, cinders, sand, mud, straw, shavings, metal, glass, rags, feathers, tar, plastics, wood, hair, fleshings, offal, entrails, paper products, etc.
6. Garbage as defined in Section 3.15 not properly shredded.
7. Septic tank, private or public treatment works plant sludge or cesspool wastes.
8. Wastewaters having an objectionable color which is not removable in the County Authority's wastewater treatment facility.
9. Any wastewater or vapor having a temperature higher than 150° Fahrenheit or 65° Centigrade.
10. Any wastewater containing fats, wax, grease, or oils, whether emulsified or not, in excess of 100 mg/l or containing substances which may solidify or become viscous at temperatures between 32° Fahrenheit and 150° Fahrenheit or 0° Centigrade and 65° Centigrade. All restaurants, garages, commercial establishments, etc., from which these substances will be discharged shall be equipped with grease traps.

11. Any wastewater containing phenolic compounds over 1.0 ppm, expressed as phenol.
12. Any wastewater having a pH value less than 5.5 or greater than 9.5 or found to be corrosive.
13. Any wastewater containing radioactive substances in excess of those permitted by N.J.A.C. 7:28-6.5
14. Any wastewater having a flash point lower than 140° Fahrenheit (60° Centigrade) as determined by the Tagliabue (Tag.) closed cup method.
15. Any wastewater with a biochemical oxygen demand (BOD) in excess of 10,000 mg/L.
16. Any wastewater with a suspended solids content in excess of 19,000 mg/L, or containing suspended solids of such character or quantity that unusual attention or expense is required to handle or treat such materials.
17. Any wastewater containing corrosive, toxic, or poisonous substances in sufficient quantity and/or concentration to cause injury, damage or hazard to personnel, structures or equipment, or interfere with the Regional or County Authority Systems or any portion of the liquid or solids treatment or handling processes, or that will pass through the treatment facilities in such condition that it will not achieve State, Federal or other existing requirements for the effluent or for the receiving waters. The following chemicals are specifically prohibited: alcohols, aldehydes, arsenic and arsenicals, bromine, chlorinated hydrocarbon, chlorine in excess of 100 ppm, chromium, copper and copper salts, cresols, cyanides, fluorine, iodine, mercury and mercurials, nickel and nickel compounds, silver and silver compounds, sulfonamides, toxic dyes (organic and mineral), zinc and zinc compounds; all strong oxidizing agents such as peroxides, chromates, dichromates, permanganates, etc., compounds producing hydrogen sulfide or any other toxic, inflammable or explosive gases either upon acidification, alkalization, reduction or oxidation; strong reducing agents such as nitrates, sulfites, sulfides; strong acids or strong alkalis.
18. Any pollutant at a flow rate or concentrations which will cause interference with the Regional Authority System.
19. Any wastewater containing substances which are not amenable to treatment or reduction by the wastewater processes employed by the County Authority, or are amenable to treatment only to such degree that the treated effluent cannot meet the requirements of other agencies having jurisdiction over its discharge to the receiving waters or which contain any substance which may cause the County Authority's sludge to be unsuitable for reclamation or reuse.

5.02 Limitations on Sulfide Discharges

In order for the Regional Sewerage System to operated properly; and to avoid any detrimental effects, particularly in the interceptor system and pump/lift stations, no Participant or person may discharge sewage into the Regional Sewerage System

wastewater which contains any total or dissolved sulfides in excess of 0.2 ppm from a gravity connection or 0.4 ppm from a forcemain connection.

5.03 Unacceptable Wastewaters

If any wastewaters are discharged, or are proposed to be discharged directly or indirectly into the Regional Authority System which contain the substances or possess the characteristics enumerated in Section 5.01 and 5.02 of this Section and which in the judgment of the Regional Authority or County Authority may have a deleterious effect upon the Regional or County Sewerage Systems, receiving waters, life, or constitute a public nuisance, the Regional Authority will exercise one or more of the following options:

1. Order the discharger of the wastes to permanently cease.
2. Order the discharge of the wastes to cease until such time as the discharger of such wastes provides a detailed report (prepared by a Professional Engineer with expertise in the treatment of industrial wastes) to the Regional Authority and County Authority containing recommendations as to the method of pretreatment and acceptability of such wastes into the Regional and County Authority Systems. Upon the Regional Authority's and County Authority's acceptance of said report, said wastes may again be accepted on a trial basis.
3. Require pretreatment to an acceptable condition for discharge to the Regional Authority System or the Local Collection Sewerage System.
4. Require control over the quality, quantity and rate of discharge of said waste.

5.04 High Strength Wastes

No statement contained in this Section shall be construed as preventing any special agreement or arrangement between the Regional Authority and County Authority and any Participant or Person whereby a wastewater with high BOD or suspended solids values, a high chlorine demand or with unusual strength or characteristics may be accepted by the Regional Authority and the County Authority for conveyance or treatment at an additional charge, provided the Regional Authority and the County Authority have determined at the expense of the Participant or Person that the wastewater can be adequately conveyed by the Regional Authority System and conveyed and treated by the County Authority System without any deleterious effects.

5.05 Categorical Pretreatment Standards

Pretreatment will be required for all industrial wastes discharged by industries as defined in 40 CFR 403 and as further detailed in Section 6.04 of the Rules and Regulations of the Ocean County Utilities Authority.

5.06 Limitations on Wastewater Discharges

Tables 1 and 2 presents the maximum concentrations of certain pollutants allowable in wastewater discharges to the treatment works by any user. Dilution of any

wastewater discharge for the purpose of satisfying these requirements shall be considered a violation of these Sewer Use Rules and Regulations.

The limits on certain pesticides, benzidine, and PCB's in Table 1 are in conformance with the Final Toxic Effluent Standards published in the Federal Register (40 CFR 129).

TABLE 1
MAXIMUM PERMISSIBLE CONCENTRATION (MG/L)

<u>Pollutant</u>	<u>1 Day Max.</u>	<u>30 Day Avg.</u>
Aldrin	*	*
Dieldrin	*	*
DDE	*	*
DDD	*	*
DDT	*	*
PCB	*	*
Endrin		
(Manufacturer, existing source)	0.0075	0.0015
(Formulator)	*	*
(Manufacturer, new source)	0.0005	0.0001
Toxaphene		
(Manufacturer, existing source)	0.0075	0.0015
(Formulator)	*	*
(Manufacturer, new source)	0.0005	0.0001
Benzidine		
(Manufacturer, existing source)	0.050	0.010
(Manufacturer, new source)	0.050	0.010
(Dye Applicators, existing source)	0.025	0.010
(Dye Applicators, new source)	0.025	0.010

* - Prohibited from discharge

TABLE 2

MAXIMUM PERMISSIBLE CONCENTRATION (MG/L)
AT OCEAN COUNTY UTILITIES AUTHORITY
NORTHERN TREATMENT PLANT

Conventional Pollutants

Parameter

BOD	10,000
TSS	19,000
pH (std. units)	5.5-9.5
Oil & Grease	100

Metals

Arsenic	0.079
Cadmium	0.066
Chromium	2.062
Copper	1.926
Lead	0.442
Mercury	0.029
Nickel	0.721
Selenium	0.061
Zinc	5.404

SECTION 6 – CONTROL OF WASTEWATER DISCHARGES

6.01 Regulatory Actions: If any water or wastewaters are discharged, or are proposed to be discharged to the Regional Authority's System, or to any sewer system tributary thereto, which waters or wastewaters contain the substances or possess the characteristics enumerated in Section 5 of these Rules and Regulations, the County Authority through the Regional Authority, or the Regional Authority, may take action necessary to:

1. Order the discharger of the wastes to permanently cease, and/or terminate sewerage services to the user.
2. Require the discharger to demonstrate that in-plant modifications will reduce or eliminate the discharge of such substances in conformity with the Rules and Regulations.
3. Require pretreatment, including storage facilities, or flow equalization necessary to reduce or eliminate the objectionable characteristics or substances so that the discharge will not violate these Rules and Regulations.
4. Require payment of a surcharge to the Regional and/or County Authority as provided in the Rules and Regulations which are intended to cover the added cost of handling and treating the loads imposed upon the Regional and County Authority Systems.
5. Take such other remedial action as may be deemed to be desirable or necessary to achieve the purpose of these Rules and Regulations.

6.02 Submission of Plans: Where pretreatment, storage, or equalization of wastewater flows prior to discharge into any part of the Regional Authority System is required, plans, specifications and other pertinent data or information relating to such pretreatment or flow-control facilities shall first be submitted to the Regional and County Authorities for review and approval. Such approval shall not exempt the discharge or the facilities from compliance with any applicable code, ordinance, rule, regulation or order of any governmental authority. Any subsequent alterations or additions to such pretreatment or flow-control facilities shall not be made without due notice to and prior approval of both the Regional and County Authority.

6.03 Protection from Accidental Discharge: Each user shall protect the Regional and County Authorities from accidental discharge of prohibited materials or other wastes regulated by these Rules and Regulations. Facilities to prevent accidental discharge to the Regional or County Authority of prohibited materials shall be provided and maintained at the owner or operator's own cost and expense. Detailed plans showing facilities and operating procedures to provide this protection shall be submitted to the Regional and County Authorities for review, and shall be approved by both the Regional Authority and by the County Authority before construction of the facility. Review and approval of such

plans and operating procedures shall not relieve the industrial user from the responsibility to modify the user facility as necessary to meet the requirements of these Rules and Regulations.

6.04 Reporting of Accidental Discharge: If, for any reason, a user does not comply with or is unable to comply with any prohibition or limitations in these Rules and Regulations, the user responsible for such discharge shall immediately telephone and notify the Regional and County Authorities so that corrective action may be taken to protect their respective systems. In addition, a written report addressed to each of the Authorities detailing the date, time and cause of the accidental discharge, the quantity and characteristics of the discharge, and corrective action taken to prevent future discharges, shall be filed by the user within five (5) days of the occurrence of the noncomplying discharge.

SECTION 7 – FLOW CHARGES AND SURCHARGES

7.01 Flow Charges: The Regional Authority shall establish annual flow charge rates in accordance with applicable provisions of New Jersey State Statute 40:14A-1 et seq. The annual flow charge rate is shown on Exhibit A - Schedule A of these Rules and Regulations. The flow charge to each Participant is computed according to the provisions of the Service Agreement with each Participant.

7.02 Surcharges: Surcharges for industrial users shall be established by the County Authority, based on schedules and methods of computation presented in the Sewer Use Rules and Regulations issued by the County Authority. Surcharges billed to the Regional Authority by the County Authority shall be billed to the Municipality in which the industry, receiving the surcharge, resides. The Regional Authority may also establish surcharges under applicable provisions of New Jersey State Statute 40:14A-1 et seq. All Regional Authority surcharges are shown on Exhibit A - Schedule B of these Rules and Regulations.

SECTION 8 – ENFORCEMENT PROCEDURES

8.01 Notification Violation: Whenever the Regional Authority finds that any Person has violated or is violating these Rules and Regulations, or any prohibition, limitation or requirement contained herein, the Regional Authority may serve upon such Person a written notice stating the nature of the violation and providing a reasonable time, as determined by the Regional Authority, but not to exceed thirty (30) days, for the satisfactory correction thereof.

8.02 Legal Action: Any unauthorized discharge into the Regional System, or any violation of the substantive provisions of these Rules and Regulations, or any violation of any Resolution or Order of the Regional Authority, shall be grounds for legal action. If any Person discharges sewage, industrial wastes or other wastes into the Regional Authority's system contrary to the substantive provisions of these Rules and Regulations, or the Rules and Regulations of the County Authority, or any Resolution or Order of the Regional Authority, the Regional Authority may commence action for appropriate legal and/or equitable relief in the Superior Court of New Jersey, located in Monmouth County, as well as any administrative relief that the Regional Authority deems appropriate..

SECTION 9 – DAMAGES AND COSTS

9.01 In addition to the charges and surcharges provided herein, in the event any authorized or unauthorized user shall violate an Order of the Regional Authority or willfully or negligently fail to comply with any provision of these Rules and Regulations, the Regional Authority may institute an appropriate action against such Person to recover the damages caused to its conveyance system as well as the costs incurred to inspect, engineer and/or rectify such conveyance difficulties as may have occurred as a result of such violation, together with reasonable attorneys' fees, court costs, court reporters' fees and others expenses of litigation.

9.02 Damages

Any person or user violating any of the provisions of these Rules and Regulations shall become liable to reimburse the Authority for any expense, loss, or damage incurred by the Authority by reason of such violation.

9.03 Penalty's for Violation

In addition to the liability for any expense, loss or damage imposed by Section 9.02 and all other remedies available to the Authority the failure of any person or user to correct a violation after notice thereof in accordance with Section 9.01 within the time specified in such notice may, in the discretion of the Authority, subject the person or user to a fine in an amount up to \$500.00 per day for each full or partial day the violation remains uncorrected.

SECTION 10 – SAVINGS CLAUSE

10.01 If any provision, paragraph, word, section or article of these Rules and Regulations is invalidated by any court of competent jurisdiction, the remaining provisions, paragraphs, words, sections and articles shall not be affected and shall continue in full force and effect.

SECTION 11 – CONFLICT

11.01 These Rules and Regulations shall be deemed to supersede all Rules and Regulations and amendments thereto which may have been previously adopted by the Regional Authority.

SECTION 12 – SPECIAL ARRANGEMENT

12.01 Nothing contained in these Rules and Regulations shall be construed as preventing any special agreement or arrangement between a Participant Municipality and any owner of property located therein upon application made and a finding by the Participant Municipality and the Regional Authority that such special agreement or arrangement would be in the best interests of the Participant Municipality and the Regional Authority.

SECTION 13 – APPLICATION FORMS

13.01 The Application forms annexed hereto shall be deemed part of these Rules and Regulations. However, the Regional Authority reserves the right to modify the Application forms and require additional or lesser documentation in support of an application at any time upon adoption by the Regional Authority's Board of Commissioners.

SECTION 14 – REVISIONS

14.01 The Regional Authority reserves the right to revise these Rules and Regulations or to adopt additional Rules and Regulations from time to time as it shall deem necessary for the operation, maintenance and protection of the Regional Authority System or for any other reason the Regional Authority deems is desirable or necessary for performing its functions.

SECTION 15 – PROTECTION FROM DAMAGE

15.01 No Person shall maliciously, willfully, or negligently break, damage, destroy, uncover, deface, or tamper with any structure, appurtenance, or equipment which is part of the Regional Authority's System. The Regional Authority will take appropriate action against any Person violating this provision.

SECTION 16 – EFFECTIVE DATE

16.01 These Amended Rules and Regulations shall be placed in full force and effect on the 18th day of July, 2013.

**MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY
RULES AND REGULATIONS**

2024 FEE SCHEDULE*

SCHEDULE “A”: **PARTICIPANT USER CHARGE:**

The flow charge fee rate for Participants is \$6,315.00 per MG effective January 1, 2024 to December 31, 2024; to be reviewed and revised annually.

SCHEDULE “B”: **SURCHARGES:**

Currently, the MRRSA is not imposing a surcharge fee, other than a direct pass through of surcharges imposed by the OCUA pursuant to Section 7.02 of these Rules and Regulations.

PLEASE NOTE: Separate checks are required for Schedule “C” and Schedule “D”

SCHEDULE “C”: **NON-REFUNDABLE FEES:**

- Application Filing (commercial, multi-unit residential of two (2) or more dwelling units and industrial uses)..... \$625.00 per filing
- Application Filing (single family residence and new non-development residence and conversion of existing residence from septic connecting to existing Participant sewer line)..... \$50.00 per filing
- Application Extension Filing..... \$250.00 per filing
- Re-Application Filing..... \$625.00 per filing
- Connection Fee..... \$2,548.00 per EDU
(Minimum connection fee for a new residential or non-residential unit is 1 EDU)
- USEPA Waiver Application..... \$200.00 per filing
- Review and endorsement for regulatory approval of projects, which are non-sewer extension related and not covered by the above application fees..... \$200.00 per review
- Returned check fee..... \$40.00 per check

SCHEDULE “D”: **ESCROW DEPOSITS:**

- Residential Developments with two 2 or less equivalent dwelling units..... \$1,500.00
- Residential, Commercial and/or Industrial Developments up to 91 equivalent dwelling units (other than above)..... \$4,000.00
- Residential, Commercial and/or Industrial Developments in excess of 91 equivalent dwelling units..... \$4,000.00 + \$33.00 per additional EDU

ADDITIONAL ESCROWS (AS APPLICABLE)

- Developments which require a USEPA Mapping Waiver..... \$1,500.00
- Direct physical connection engineering inspection fees..... \$2,000 per connection
- Miscellaneous and informal reviews..... Appropriate amount determined by the MRRSA Executive Director based upon the estimated amount of time and work required

***Note to Schedule "D": Applicants will be notified of any deficiency in the amount of the escrow deposit if the actual engineering, attorney and administrative fees that the Authority incurred exceeds the amount of the initial escrow deposit. The Authority shall notify the Applicant of the additional amount required to fund the escrow deposit in an amount that the Authority projects the additional costs and fees incurred by the Authority will be. The Applicant must deposit the additional escrow with the Authority within fourteen days after receiving notice from the Authority. Further processing of the application will not occur until the additional escrow fees have been deposited with the Authority.*

The definition of an equivalent dwelling unit (EDU) is herewith defined to be the same as "the equivalent unit" set forth in Section 3.13, 3.13.A and 3.13.B of the Rules and Regulations.

**PLEASE NOTE: All fees are subject to review and change. Please contact the Authority at (732) 431-8185 prior to remittance.*

EFFECTIVE: JANUARY 1, 2024

- 3.13 “Equivalent Dwelling Unit” shall mean the equivalent wastewater flow from one three bedroom single family dwelling unit and shall be applied to residential, industrial, commercial and other users at an average rate of 300 gallons per day.
- 3.13.A. “Equivalent Dwelling Unit (Non-Residential Calculation)” The Authority’s Engineer shall determine the equivalent wastewater flow from the proposed non-residential use by reference to the NJDEP flow standards published within N.J.A.C. 7:14A-23.3 where available; or based upon comparable use flows as determined by the Authority’s Engineer using the best available information. The amount of flow determined in gallons per day shall be divided by 300 to determine the number of Equivalent Dwelling Units of sewage to be used to calculate connection fees.
- 3.13.B. “Equivalent Dwelling Unit (Residential Calculation)” shall be based upon the number of bedrooms proposed for each residential dwelling. In computing the equivalent wastewater flow from a proposed residential use to be used to calculate connection fees, the following adjustments shall be made where 1 EDU as defined above equates to 300 gallons per day:
1. Residential dwellings with one bedroom shall be equivalent to 0.50 EDU
 2. Residential dwellings with two bedrooms shall be equivalent to 0.75 EDU
 3. Residential dwellings with three or four bedrooms shall be equivalent to 1.0 EDU
 4. Residential dwellings with more than four bedrooms shall be equivalent to 1.25 EDU

Where a residential dwelling contains more than three bathrooms, and/or more than one kitchen area, and/or more than one laundry area, or provides for some other use on the residential property which will cause additional sewerage flow; the Authority’s Engineer shall determine the reasonable amount of additional equivalent sewer usage to be added to the EDU’s determined above.

APPLICATION FOR SEWER CONNECTION

APPLICATION NO. _____ FILING DATE _____

MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY
89 HAVENS BRIDGE ROAD
FARMINGDALE, NJ 07727

APPLICATION FOR REVIEW OF PLANS FOR SEWER EXTENSIONS TO SERVICE RESIDENTIAL OR COMMERCIAL SUBDIVISIONS OR OTHER DEVELOPED AREAS AND/OR WASTEWATER TREATMENT FACILITIES IN THE MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY SERVICE AREA, COUNTY OF MONMOUTH, STATE OF NEW JERSEY. (This application must be filed in duplicate and accompanied by the applicable fees shown on Schedules C & D).

Application is hereby made for review of plans of proposed sewer application, and for authorization and approval of discharge of sewage within the Manasquan River Regional Sewerage Authority's service area.

1A. Applicant's Name _____

Address _____ Phone: _____

1B. Developer's Name: _____

Address: _____

2. Location of Area to be Sewered: _____
(Municipality)

(Streets)

(Tax map block) (Tax map lot #'s)

3. Brief description of type of users and area to be sewered:

EXHIBIT B

4. Number of proposed lots or units to be sewerd: _____

5. Area of tract or commercial building being sewerd: _____

6. If commercial, type of establishment and estimated wastewater flow or industrial (NOTE: If Industrial, attach copy of OCUA Industrial Discharge Permit Application):

7. Location of point of connection to Authority or Municipal System: _____

8. Name and profession of person designing sewerage system.

(Name)

(Profession)

9. Estimated stating date _____ Completion date _____

10. Include the following with application:

- ___ A. (3) sets of plans, specifications and engineer's reports (signed and sealed)
- ___ B. (3) Township Resolutions – authorizing township engineer to endorse TWA-1 Forms
- ___ C. (3) Planning Board Resolutions – granting application preliminary or final approval
- ___ D. (3) TWA-1 Forms and NJDEP WQM-006 Forms (signed and sealed)
- ___ E. (3) NJDEP WQM-003 Forms (with township endorsement)
- ___ F. (3) OCUA Applications, original signatures required (owner and township)
- ___ G. (3) tax certification forms (W-9), with tax identification # or social security #, signed with authorized signature (part of application forms)
- ___ H. (3) For projects with pumping stations, engineer reports of design (signed and sealed)
- ___ I. (3) For projects with wetlands, packets per Waiver Request Checklist and or Mapping Revision Request

Signature of Applicant: _____ Date: _____

EXHIBIT B

Date received and fees collected:

Date: _____	Application Fee Paid: _____
Date: _____	Escrow Paid: _____
Date: _____	EPA Waiver Fee _____
Date: _____	Connection Fees Paid: _____
Date: _____	Time Extension Paid: _____
Date: _____	Re-Application Paid: _____

Recommendations of the Authority Engineer _____

Action of the Manasquan River Regional Sewerage Authority:

Date: _____ Approved: _____

THE HEREIN APPLICATION SHALL BE SUBMITTED FOR ENDORSEMENT TO THE OCEAN COUNTY UTILITIES AUTHORITY, NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION AND THE APPROPRIATE LOCAL AGENCIES, IF REQUIRED.

EXHIBIT B

APPLICATION FOR INSPECTION OF DIRECT CONNECTION

APPLICATION NO. _____ FILING DATE: _____

MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY
89 HAVENS BRIDGE ROAD
FARMINGDALE, NJ 07727

APPLICATION FOR INSPECTION OF DIRECT CONNECTION TO THE MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY SEWERAGE SYSTEM, MONMOUTH COUNTY, NEW JERSEY. (This application must be filed in duplicate. Notification of the connection construction must be made to the Authority at least 72 hours in advance of the connection date.)

Application is hereby made for permission to excavate and make direct connection to the Manasquan River Regional Sewerage Authority sewerage system.

1. Applicant's Name: _____

Address: _____

2. Developer's Name: _____

Address: _____

3. Development Name: _____

4. Estimated Date of Connection: _____

Signature of Applicant: _____ Date: _____

MAKE ALL CHECKS PAYABLE TO THE MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY.

DATE: _____

FEE PAID: _____

EXHIBIT C

APPLICATION FOR SEWER – SINGLE DWELLING

APPLICATION NO. _____

FILING DATE: _____

MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY
89 HAVENS BRIDGE ROAD, P.O. BOX 646
FARMINGDALE, NJ 07727

APPLICATION FOR REVIEW OF PLANS FOR SEWER TO SERVE RESIDENCES IN THE MANASQUAN RIVER REGIONAL SEWERAGE AUTHORITY SERVICE AREA, COUNTY OF MONMOUTH, STATE OF NEW JERSEY. (This application must be filed in duplicate and accompanied by the applicable fees shown on Schedule C.)

1. Applicant Name: _____
Address: _____ Phone: _____

2. Location of area to be sewered: _____
(municipality)

_____ (street address)
Block _____ Lot _____

3. Number of proposed lots or units to be sewered: _____

4. Location of point of connection to Authority or Municipal system:

5. Estimated starting date: _____ completion date: _____

Signature of application: _____ Date: _____

Make all checks payable to the Manasquan River Regional Sewerage Authority

Date received and fee collected:

Date: _____

Fee paid: _____

EXHIBIT D